#### **ADDENDUM #2**

1	. 1	PR	CO.	ΙF	CT	IN	FΩ	RI	MΔ	ιТΙ	$\bigcirc$	١

A. Project Number: 2022-617

B. Project Title: Geiger Field Building 401 Roof Repair

C. Project Location: 8922 W. Electric Avenue

Spokane, WA 99224

D. Agency: Washington Military Department, Army National Guard

#### 1.2 NOTICE TO BIDDERS

- A. The following clarifications, changes, additions, and/or deletions are considered Addendum No. 2, and are hereby made a part of the contract documents. All bidders are required to base their bid upon the information furnished in this addendum and as required in the contract documents. The Contractor is required to acknowledge Addendum No. 2 in their company proposal. Failure to acknowledge addendum on the bid form will result in the bid proposal being declared non-responsive.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this addendum.

## 1.3 ATTACHMENTS

- A. This Addendum includes the following attached documents:

### 1.4 CLARIFICATONS

A. Bookmark in spec incorrectly indicates a section "077710 - FALL RESTRAINTS". Disregard. There are no fall restraints specified for this project.

### 1.5 REVISIONS TO SPECIFICATIONS

A. None

### 1.6 REVISIONS TO DRAWINGS SHEETS

A. Sheet A-201 Roof Plan, ADD note:

ELECTRICAL CONDUIT FASTENED DIRECLTY UNDER DECK. SEE PHOTO 3/A-301

FULLY ADHERE NEW ROOF SYSTEM TO DECK. DO NOT SCREW THROUGH DECK.

### **END OF ADDENDUM #2**

May 8, 2023 Addendum #2-1

# ATTENDANCE SHEET

rle irm Architectural Company  Farling irm Architectural Company  saldanha irm itary Dept	Role QA/QC observer  Role Architectural Associate  Role Project Manager	Phone 509-363-1039 Email bill@cortner-ps.com  Phone 509-363-1039 Email alan@cortner-ps.com
irm Architectural Company  saldanha	Architectural Associate  Role	509-363-1039 Email
irm		
	r Ioject Managei	Phone 253-512-8404 Email Sachin.saldanha@mil.wa.gov
an Halme Ime Builders	Role Presidet	Phone Sog - 725 - 1266 Email dane balane bailders. Com
RY HAAS irm v corp.	Role SUPER INTEROSM	Phone  509532 1761  Email  ALLAN @ICON ROOFING, COM
an Scribner m D7	Project Engineer	Phone 268-215-440> Email ASCRIBNER CAXIOMA 7. NET
PILLERS EER SM	Role PROSECT MANGER	Phone 509 489 072) Email DOW, PILLERS @ KRUEGER SHEFT METAL, COM
irm	Role	Phone Email
8	Role	Phone Email
	ER SM	Role Role Role