

## Addendum No. 4

**Project:** Building 3 Remodel  
Building 3, 3 Infantry Drive  
Camp Murray, WA 98430  
State Project No. 2022-609

**KMB Job No.:** 22052

**Issue Date:** May 11, 2023

**Bid Date:** May 18, 2023

**To:** All Plan Holders

**From:** Atika Jain, Project Manager

The following modifications to the Project Manual, Specifications and/or Drawings are to be incorporated into bid proposals that may be offered, and the subsequent construction. Bidders shall assess and include the full impact of the revision(s) on any and all related systems and work. Receipt and incorporation of this Addendum in the bid proposal shall be indicated on the Bid Form in the space provided.

---

### GENERAL:

#### Item Description

#### 1. CLARIFICATION – Q & A:

Note: All pre-bid meeting and any subsequent conversations and observations are considered informal and are not contractually binding unless stated in the contract manual, drawings, or modified by a written addendum. Questions posed to KMB and answers provided by electrical engineer.

**Question:** The specs call for a Neutral Host Distributed Antenna System capable of supporting Wireless Service and Public Safety Network. If the AHJ does not allow co-mingling of Public Safety and Cellular on the same DAS can a standard BDA/DAS be installed?

**Answer:** Yes, a standard BDA/DAS System is adequate for this site per Pierce County.

**Question:** For this size of building, can a standard BDA/DAS be installed instead of a Neutral Host DAS and without the expandability of adding Cellular to the system?

**Answer:** Yes, a standard BDA/DAS System is adequate for this site per Pierce County without Cellular.

**Question:** If standard BDA/DAS is allowed, can Comba, Fi-Plex be substituted for CommScope/Andrew?

**Answer:** Yes, alternatives will be accepted for review.

**Question:** The 20-year warranty on cables, splitter, and tappers (passive components) is not an industry standard. Can this be omitted?

**Answer:** Please include a 5-year warranty. 20-year warranty can be omitted.