

WASHINGTON MILITARY DEPARTMENT  
BUILDING 19 HVAC REPLACEMENT  
STATE PROJECT NO. 2022-616

**ADDENDUM NO. 2**

5-31-23

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents as described. Acknowledge receipt of this Addendum in the space provided on the Form of Proposal. Failure to do so may subject Bidder to disqualification. There are 2 pages to this addendum including all attachments. This Addendum is issued to all known Plan Holders.

**PRE-BID WALK-THROUGH**

1. A pre-bid walk-through was held May 23, 2023; see the attached sign-in sheet for attendees. Issues and questions discussed in the walk-through and during bidding have been answered in this Addendum. Where not answered in this Addendum the issue or question is already answered in the Contract Documents with no further clarification felt to be required.

**DRAWINGS**

1. Sheet G1.0, Work Limitations, **ADD** Note 7: "TELECOM ROOM 106 MAY NOT BE WITHOUT AIR CONDITIONING AT ANY TIME. CONTRACTOR SHALL PHASE INSTALLATION SUCH THAT EITHER AC-4 OR AC-5 AND AC-6 ARE OPERATIONAL AT ALL TIMES."
2. Sheet G1.0, Work Limitations, **ADD** Note 8: "DEMOLITION ON A PIECE OF EQUIPMENT MAY NOT OCCUR UNTIL ITS CORRESPONDING REPLACEMENT UNIT IS ON SITE, READY FOR INSTALLATION."
3. Sheet ME1.1, **REVISE** Keyed Note 6 to read: "EXISTING PIPING RUNS THROUGH ATTIC. SHOWN HERE FOR CLARITY."
4. Sheet ME2.1, **DELETE** all hexagon callout symbols shown inside equipment outlines.
5. Sheet ME2.1, **REVISE** Keyed Note 3 to read: "RUN PIPING IN ATTIC SPACE. SHOWN HERE FOR CLARITY. PIPING SHALL BE RUN IN SUCH A MANNER AS TO NOT OBSTRUCT ACCESS THROUGH ATTIC."
6. Sheet ME2.2, **DELETE** all hexagon callout symbols shown inside equipment outlines.
7. Sheet ME2.2, **REMOVE** and **RELOCATE** existing disconnect as necessary to install new attic access door. Extend conduit and wiring as necessary to accommodate relocation.

**ATTACHMENTS**

1. Pre-Bid Sign-In Sheet, 1 page

END OF ADDENDUM

# Meeting Attendance Roster

HB

Project: 2022-616 Camp Murray bldg 19 HVAC Replacement

HBHU Job# 22-181

Date: May 23, 2023

Purpose: Pre-Bid Walk-Through

Time: 9:00 AM

Location: Camp Murray Bldg 19

Page: 1

Name	Representing	Phone	Email
Brian White	Hultz BHU Engineers	253.383.3257	brianw2hultzbbhu.com
Bill Schmidt	Capital Heating & Cooling	360 239-8045	Bill@Capitalkheatingandcooling.com
Guy Hamilton	Crescent Mechanical	253 833 5084	guy@cvcsentrmec.com
John Boyer	Reliable Electric	360-701-1904	john@reliableelectric.biz
Will Barry	Centennial	253-577-5483	wharry@ce-inc.com
Jerry Boone	WMID	253-538-6502	Jerry.J.Boone@wmid.com
Paul O'Neil	SA Morris Construction	360 556 4439	paul@samorris.com
Curry Gillette	TRC mech	253-260-2594	Curry@TRCmech.com
JERRY BOONE	Camp MURRAY	253-512-8940	JERRY.BOONE@MIL.WA.GOV