

ADDENDUM #2

1.1 PROJECT INFORMATION

- A. Project Number: 2022-622
- B. Project Title: Moses Lake (Armory) HVAC Replacement
- C. Project Location: 6500 32nd Avenue NE, Moses Lake, WA
- D. Agency: Washington Military Department, Army National Guard

1.2 NOTICE TO BIDDERS

- A. The following clarifications, changes, additions, and/or deletions are considered Addendum No. 2, and are hereby made a part of the contract documents. All bidders are required to base their bid upon the information furnished in this addendum and as required in the contract documents. The Contractor is required to acknowledge Addendum No. 2 in their company proposal. Failure to acknowledge an addendum on the bid form will result in the bid proposal being declared non-responsive.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.

1.3 ATTACHMENTS [NONE]

1.4 REVISIONS TO SPECIFICATIONS [NONE]

1.5 REVISIONS TO DRAWINGS SHEETS

- A. SHEET M-201 LEVEL 1 HVAC, GENERAL NOTES
ADD:
 - 6. ALL EXISTING VOLUME DAMPERS ARE TO REMAIN IN THEIR AS-BUILT CONDITIONS (SUPPLY, RETURN, EXHAUST, OUTSIDE AIR). RE-BALANCING OF AIR DISTRIBUTION AND OUTSIDE AIR VOLUMES IS NOT REQUIRED.

END OF ADDENDUM #2